

Equipment/Task	Engineering and Work Practice Control Methods	Required Respiratory Protection and Minimum Assigned Protection Factor (APF)		What does <i>full and proper</i> implementation require?*
		≤ 4 hours /shift	> 4 hours /shift	
(vi) Rig-mounted core saws or drills	<ul> <li>Use tool equipped with integrated water delivery system that supplies water to cutting surface.</li> <li>Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.</li> </ul>	None	None	Water Controls:  ■ An adequate supply of water for dust suppression is used;  ■ The spray nozzles produce a pattern that applies water at the point of dust generation;  ■ The spray nozzles are not clogged or damaged; and  ■ All hoses and connections are intact.
(vii) Handheld and stand-mounted drills (including impact and rotary hammer drills)	<ul> <li>Use drill equipped with commercially available shroud or cowling with dust collection system.</li> <li>Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.</li> <li>Dust collector must provide the air flow recommended by the tool manufacturer, or greater, and have a filter with 99% or greater efficiency and a filter-cleaning mechanism.</li> <li>Use a HEPA-filtered vacuum when cleaning holes.</li> </ul>	None	None	Dust Collection Systems:  ■ The shroud or cowling is intact and installed in accordance with the manufacturer's instructions;  ■ The hose connecting the tool to the vacuum is intact and without kinks or tight bends;  ■ The filter(s) on the vacuum are cleaned or changed in accordance with the manufacturer's instructions; and  ■ The dust collection bags are emptied to avoid overfilling.



Equipment/Task	Engineering and Work Practice Control Methods	Required Respiratory Protection and Minimum Assigned Protection Factor (APF)		What does <i>full and proper</i> implementation require?*
		≤ 4 hours /shift	> 4 hours /shift	
(x) Jackhammers and handheld powered chipping tools	Use tool with water delivery system that supplies a continuous stream or spray of water at the point of impact.  When used outdoors.  When used indoors or in an enclosed area.  OR  Use tool equipped with commercially available shroud and dust collection system.  Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.  Dust collector must provide the air flow recommended by the tool manufacturer, or greater, and have a filter with 99% or greater efficiency and a filter-cleaning mechanism.  When used outdoors.  When used indoors or in an enclosed area.	None APF 10  None APF 10	APF 10 APF 10 APF 10	Water Controls‡:  ■ An adequate supply of water for dust suppression is used;  ■ The water sprays are working properly and produce a pattern that applies water at the point of dust generation;  ■ The spray nozzles are not clogged or damaged; and  ■ All hoses and connections are intact.  Dust Collection Systems:  ■ The shroud is intact and installed in accordance with the manufacturer's instructions;  ■ The hose connecting the tool to the vacuum is intact and without kinks or tight bends;  ■ The filter(s) on the vacuum are cleaned or changed in accordance with the manufacturer's instructions; and  ■ The dust collection bags are emptied to avoid overfilling.



Equipment/Task	Engineering and Work Practice Control Methods	Required Respiratory Protection and Minimum Assigned Protection Factor (APF)		What does <i>full and proper</i> implementation require?*
		≤ 4 hours /shift	> 4 hours /shift	
(xi) Handheld grinders for mortar removal (i.e., tuckpointing)	Use grinder equipped with commercially available shroud and dust collection system.  Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.  Dust collector must provide 25 cubic feet per minute (cfm) or greater of airflow per inch of wheel diameter and have a filter with 99% or greater efficiency and a cyclonic preseparator or filter-cleaning mechanism.	APF 10	APF 25	Dust Collection Systems:  ■ The shroud is intact, encloses most of the grinding blade, and is installed in accordance with the manufacturer's instructions;  ■ The hose connecting the tool to the vacuum is intact and without kinks or tight bends;  ■ The filter(s) on the vacuum are cleaned or changed in accordance with the manufacturer's instructions;  ■ The dust collection bags are emptied to avoid overfilling;  ■ The blade is kept flush against the surface whenever possible; and  ■ The tool is operated against the direction of blade rotation, whenever practical.



Equipment/Task	Engineering and Work Practice Control Methods	Required Respiratory Protection and Minimum Assigned Protection Factor (APF)		What does <i>full and proper</i> implementation require?*
		≤ 4 hours /shift	> 4 hours /shift	
(xii) Handheld grinders for uses other than mortar removal	For tasks performed outdoors only:  Use grinder equipped with integrated water delivery system that continuously feeds water to the grinding surface.  Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.  OR  Use grinder equipped with commercially available shroud and dust collection system.  Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.  Dust collector must provide 25 cubic feet per minute (cfm) or greater of airflow per inch of wheel diameter and have a filter with 99% or greater efficiency and a cyclonic preseparator or filter-cleaning mechanism.  When used outdoors.  When used indoors or in an enclosed area.	None None None	None None APF 10	Water Controls <sup>§</sup> :  ■ An adequate supply of water for dust suppression is used;  ■ The spray nozzles are working properly and produce a pattern that applies water at the point of dust generation;  ■ The spray nozzles are not clogged or damaged; and  ■ All hoses and connections are intact.  Dust Collection Systems:  ■ The shroud is intact and installed in accordance with the manufacturer's instructions;  ■ The hose connecting the tool to the vacuum is intact and without kinks or tight bends;  ■ The filter(s) on the vacuum are cleaned or changed in accordance with the manufacturer's instructions; and  ■ The dust collection bags are emptied to avoid overfilling.



CONCRETE				
Equipment/Task	Engineering and Work Practice Control Methods	Required Respiratory Protection and Minimum Assigned Protection Factor (APF)		What does <i>full and proper</i> implementation require?*
		≤ 4 hours /shift	> 4 hours /shift	
(iv) Walk-behind saws	Use saw equipped with integrated water delivery system that continuously feeds water to the blade.  Operate and maintain tool in accordance with manufacturer's instructions to minimize dust emissions.  When used outdoors.  When used indoors or in an enclosed area.	None APF 10	None APF 10	Water Controls:  ■ An adequate supply of water for dust suppression is used;  ■ The spray nozzles are working properly to apply water at the point of dust generation;  ■ The spray nozzles are not clogged or damaged; and  ■ All hoses and connections are intact.